



NOTES:  
 1. THIS DRAWING IS THE PROPERTY OF DELAP & WALLER AND MAY ONLY BE USED WITH THEIR WRITTEN APPROVAL.  
 2. DO NOT SCALE FROM THIS DRAWING.

- ELECTRICAL SYMBOLS**
- 6m COLUMN MOUNTED 18W LED FITTING TO IP68 IK08 PUBLIC LIGHTING PILLAR
  - ESB MINI PILLAR & VC2 VAULT. LOCATION SUBJECT TO CONFIRMATION BY ESB
  - JB1 PUBLIC LIGHTING CHAMBER
  - 3X6SQ SWA CABLE LAID IN DUCTING TO DCC STANDARDS
  - 100mm DUCT BETWEEN COLUMNS
  - 50mm DUCT BETWEEN MINI-MIDI PILLARS
  - 600mm (W) x 600mm (L) x 1000mm (D) PREFABRICATED ELECTRICAL MANHOLE / CHAMBER C/W HEAVY DUTY GALVANISED STEEL LID
  - OUT-OF BOUNDARY LIGHTS. SHOWN FOR CALCULATION PURPOSES ONLY.

- GENERAL NOTES**
- ALL UTILITIES DETAILS ARE TYPICAL SUBJECT TO RECEIPT OF UTILITIES COMPANY LAYOUT DUCTING DETAILS.
  - CONTRACTOR SHALL TO PROVIDE COORDINATED SITE SERVICES INSTALLATION DRAWINGS PRIOR TO THE COMMENCEMENT OF WORKS
  - SINGLE WALL DUCTING, COLOUR RED TO BE USED MANUFACTURED FROM HIGH DENSITY POLYETHYLENE (H.D.P.E.), 107MM EXTERNAL DIAMETER, HAVING A WALL THICKNESS OF 5MM. THIS DUCTING TO HAVE THE WORDS 'STREET LIGHTING' STAMPED ON, LETTER SIZE 9MM AT 1M INTERVALS. THE LETTERING TO FACE UPPERMOST IN THE TRENCH. ALL WORKS TO DCC PUBLIC LIGHTING SPECIFICATION.
  - THIS IS A CIRCUIT LAYOUT AND NOT INDICATIVE OF WHERE DUCTS ARE TO BE LAID.
  - GALVANIZED STEEL COLUMNS TO BE USED FOR LIGHTING INSTALLATIONS. COLUMN MUST BE MANUFACTURED AND INSTALLED IN ACCORDANCE WITH DCC PUBLIC LIGHTING SPECIFICATION AND RELEVANT STANDARDS.

T01	SJ	ISSUED FOR TENDER	13/08/24
REV BY	DESCRIPTION	DATE	
PROJECT: CLONGRIFFIN			
www.delapandwaller.com		Antrim: T +44 (0) 28 9448 3900	
info@delapandwaller.com		Dublin: T +353 (0) 1 535 5900	
		London: T +44 (0) 20 8059 7373	
CLIENT: LDA			
ARCHITECT: CCK			
SCALE AT A1: 1:400 @A1	CHK: NN	APP: JB	
	DES: SJ	DRW: SJ	
WORK PACKAGE: M&E DESIGN			
DRAWING TITLE: PUBLIC LIGHTING LAYOUT			
DRAWING NUMBER: 23113-L00-DR-DLW-E-1303			
STATUS: TENDER			REV: T01